



"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"




Delhi Jal Board

DELHI JAL BOARD  
(GOVT. OF N.C.T. DELHI)  
QUALITY CONTROL ZONAL LABORATORY (SOUTH)  
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015



Dated:19.10.2023

No. DJB/DTQC/ CWA (W&S)III / ACWA (south)/ Bact/P.S./2023-2024/070-071/17.10.2023

Bacteriological Analysis Report as per IS 10500:2012

To M/s Don Bosco School

Alaknanda, Kalkaji

New Delhi -110019

Party Ref.No./Date: Nil/Dt. 05.10.2023

Deptt.Challan No. /date: 302/05.10.2023

Dt.of sample collection: 17.10.2023

No. of Sample: Two(02)

Collected by: Name- Mr. T.N. Rai

Desig.- A.C.W.A

SL.No.	Particulars	Clarity	Residual chlorine	Total coliform/ E.coli in 100 ml sample
1.	UGT Near Pump House, Don Bosco School	Clear	0.60	0
2.	After R.O Ground floor Drinking Point	Clear	Nil	0

RESULT:- Collected water sample as mentioned above at Sr.No. 1, 2 were found bacteriologically satisfactory, hence the water/source is fit for drinking/recreational purpose subject to satisfactory attached Physical-Chemical Analysis report also.

19/10/23  
ACWA (SOUTH)

19/10/2023  
BACTERIOLOGIST(SOUTH)

19/10/23  
ASSTT/BACT.

ATTESTED BY  
  
Principal  
Don Bosco School  
Alaknanda  
New Delhi 110019



**MUNICIPAL CORPORATION OF DELHI**  
**PUBLIC HEALTH DEPARTMENT : SOUTH ZONE**  
**GREEN PARK, AUROBINDO MARG NEW DELHI 110016**

No: DHO/SZ/MCD/2023/D- 1412

Dated .....14/8/23

**SCHOOL HEALTH CERTIFICATE**

1. Name of the School	Don Bosco Sachool			
2. Address	Alaknanda, New Delhi-110048			
3. No. of Shift	Morning	Timing	8AM to 2PM	
4. No. of Students: Boys	2231	Girls	0	Total 2231
5. No. of Staffs: Male	50	Female	79	Total 129

**Details of Accommodations present in School**

1. Floor Space in the Classroom Sufficient/insufficient : Sufficient
2. The Classrooms are Well Lighted/ ill lighted : Well Lighted
3. The Classrooms are Well Ventilated/ ill ventilated : Well Ventilated
4. The Classrooms are kept / Not kept Neat & Clean: kept Neat & Clean
5. The Classrooms/Building requires/ do not required Whitewash etc. Whitewash
6. The Drinking Water is Wholesome/ not wholesome : Drinking Water is Wholesome
7. The Latrine arrangement is Sanitary/ insanitary : Sanitary

**No. of toilets seats for student**

1. One latrine-cum-urinal is required for 25 female students are sufficient.
2. One latrine for 40 male students is required is sufficient.
3. Separate Toilet arrangement for staff present: Yes/No : Yes
4. The Overall facilities: Good/ Adequate/Inadequate : Good

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

(Remarks: Certificate is valid for One Year)

*Dr. Anil Kumar*  
14/8/2023  
Deputy Health Officer  
South Zone, MCD  
Dy. Health Officer/SZ

ATTESTED BY  
*Dr. Anil Kumar*  
Principal  
Don Bosco School  
Alaknanda  
New Delhi 110048